

**Copy of the Certificate regarding Water, Health & Sanitation issued by
Taluka Health Officer, Dhoraji**

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.01

Date:08.05.2026

It is-a certified an inspection team headed by,MEDICAL OFFICER OF PRIMARY HEALTH CENTRE, DHORAJI inspected the building URJA SCHOOL OF EXCELLENCE, NEAR RAILWAY CROSSING, JAMNAVAD ROAD, DHORAJI, RAJKOT - 360410, GUJARAT on 08.05.2026 and on the basis of water Test report (attached) bearing no. 01 Dated 06.02.2026 of TALUKA LABORATORY, JETPUR. certified that the URJA SCHOOL OF EXCELLENCE has safe drinking water facilities for the students and member of staff of the institution school is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T Govt.

The certificate is valid till THREE YEARS.



Signature with Seal

Taluka Health Officer,
Name: **Dhoraji.**

Designation: **MEDICAL OFFICER**

Name & Address of the Office / **PRIMARY HEALTH CENTRE,**
Department: **DHORAJI**

TO,
MANAGER,
URJA SCHOOL OF EXCELLENCE
DHORAJI


Principal,
Urja School of Excellence
Jamnavad, Dhoraji

Urja School of Excellence - Jamnavad


Managing Trustee

Copy of the water Examination Report

TL /7.8/F-01



Taluka Laboratory
O/o The Dy Exe.Engineer,
Public Health Sanitary Sub Division,
Gujrat Water Supply & Sewerage Board,
Taluka Seva Sadan, 3rd Floor, Junagadh Road,
Jetpur-360370



Test Report

Name & Address of Customer:-

Urja School Of Excellence
Managed By Global Education Trust
At. Jamanavad
Ta. Dhoraji
DIST- RAJKOT

Customer Reference No.:

Sample Submitted by :
Date of Sample Receipt :
Analysis Starting Date :
Analysis Completion Date :
Discipline : Chemical Testing

Sender
30-Jan-26
31-Jan-26
31-Jan-26
Group : Water

Test Report No.:	1	Discipline : Chemical Testing		Group : water
Sample ID :	TJCW-1471/11/2025		Date of Issue :	31-Jan-26
Main Source :	Surface water		Mode of Sample:	
Location :	Urja School		Source :	Filter Water R O
Village :	Jamanavad		Habitation :	0
Taluka :	Dhoraji		District :	Rajkot
Latitude :	0		Longitude :	0
Kindly find herewith the Analytical Results.			Sample Type:	Drinking Water
Sr. No.	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	Hazen	APHA (23 rd Ed.2017), Method: 2120 C	1.04
2	Odour	-	IS:3025 (part 5) -2018	Agreeable
3	Taste	-	IS:3025 (part 8) -1984	Agreeable
4	Turbidity	NTU	APHA (23 rd Ed.2017), Method: 2130 B	0.78
5	pH at 25 ⁰ C	-	APHA (23 rd Ed.2017) Method: 4500 H ⁺ B	7.08
6	Total Dissolved Solids	mg/l	APHA (23 rd Ed.2017) Method: 2540 C	342
7	Total Hardness (as CaCO ₃)	mg/l	APHA (23 rd Ed.2017) Method: 2340 C	220
8	Calcium (as Ca ⁺²)	mg/l	APIIA (23 rd Ed.2017) Method: 3500 Ca ⁺² B	43
9	Magnessium (as Mg ⁺²)	mg/l	APIIA (23 rd Ed.2017) Method: 3500-Mg ⁺² B	28
10	Chloride (as Cl ⁻)	mg/l	APIIA (23 rd Ed.2017) Method: 4500-Cl ⁻ B	200
11	Sulphate (as SO ₄ ⁻²)	mg/l	APHA (23 rd Ed.2017) Method: 4500-SO ₄ ⁻² E	36
12	Nitrate (as NO ₃ ⁻)	mg/l	APIIA (23 rd Ed.2017) Method: 4500-NO ₃ ⁻ B	0.59
13	Fluoride (as F ⁻)	mg/l	APHA (23 rd Ed.2017) Method: 4500-F ⁻ C	0.28
14	Total Alkalinity (as CaCO ₃)	mg/l	APHA (23 rd Ed.2017) Method: 2320 B	160

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500:2012 (2nd Revision) limits.
5. Name & Address Of Customer & details of Sample are Provided by the Customer.

Checked By

Name & Designation of Authorized Signatory
Alpa M. Hirpara (Chemist)

End of the Test Report

O.W.No. TLJE / JET / C.Report / 145 of 2026 D^o 6 to 2/2026

Principal,
Urja School of Excellence
Jamnavad, Dhoraji

Urja School of Excellence - Jamnavad

Managing Trustee

IS-10500:2012 (2nd Revision)

Sr. No.	Parameter	Unit	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
			Max.	Max.
1	Colour	Hazen	5	15
2	Odour	-	Agreeable	Agreeable
3	Taste	-	Agreeable	Agreeable
4	Turbidity	NTU	1	5
5	pH at 25°C	-	6.5 to 8.5	No relaxation
6	Conductivity at 25°C	µS/cm	-	-
7	Total Dissolved Solids	mg/l	500	2000
8	Total Hardness (as CaCO ₃)	mg/l	200	600
9	Calcium (as Ca)	mg/l	75	200
10	Magnesium (as Mg)	mg/l	30	100
11	Chloride (as Cl)	mg/l	250	1000
12	Sulphate (as SO ₄)	mg/l	200	400
13	Nitrate (as NO ₃)	mg/l	45	No relaxation
14	Fluoride (as F)	mg/l	1	1.5
15	Total Alkalinity (as CaCO ₃)	mg/l	200	600


Principal,
Urja School of Excellence
Jamnavad, Dhoraji

Urja School of Excellence - Jamnavad


Managing Trustee